

9.11 ZPCD Pressure test set (large one).

A set for pressure tests of tightness of heat-shrinkable, welded and also steel connections, pursuant to the requirements of the PN-EN 489:2020-01 Standard. According to that requirements the tightness of all connections is to be tested.

Pressure test shall be performed prior to foaming of PUR, in case of heat-shrinkable and welding joints - after the tested joint is fully cooled down. It is recommended to perform the test at a temperature of $\leq 35^{\circ}\text{C}$. The fluids used for tests can't affect the jacket pipe, the joint and the environment.

SET CONTAINS:

- pump with end plug and manometer
- additional end plug with vent valve
- sprinkler
- bottle for fluid soap
- set of rubber plugs for heat-shrinkable and welded joints

***Please note:** The appearance of set and its components may differ slightly from that in the image.



9.12 An isopropanol alcohol for cleaning the surface of the jacket pipe.



9.13 Dust-free cleaning tissues.



| ITEM | Container's capacity [dm ³] | CATALOGUE No. |
|---------------------|-----------------------------------------|---------------|
| Isopropanol alcohol | 1 | IPA-1 |
| Isopropanol alcohol | 5 | IPA-5 |

| ITEM | CATALOGUE No. |
|----------------------------|---------------|
| Dust-free cleaning tissues | CHB-280 |